



# TYPICAL STEAM GENERATOR TUBE RUPTURE (SGTR) EFFECT ON THERMO-HYDRAULIC PARAMETERS OF VVER-1000 PRIMARY LOOP

**Abbas zare & MohammadReza Nematollahi**

Engineering school of Shiraz University, Iran

**The 13th International Conference on Emerging Nuclear Energy Systems  
(ICENES2007)**

## Objectives and content of the presentation

- Introduction
- VVER 1000 Nuclear Power Plant Description
- Description of the SGTR scenario
- RELAP5/MOD3.2 Model
- Initial Conditions
- Transient scenario
- Results and discussion
- Conclusions

# Investigation of a steam generator tube rupture accident

## Introduction

In the operation of nuclear power plants, it is very important to evaluate different accident scenarios in actual plant conditions. One of them is Steam Generator Tube Rupture (SGTR) in the field of nuclear safety.

The purpose of this research is to estimate the variation of thermo-hydraulics parameters in a primary loop under SGTR accidents in a VVER-1000 nuclear power plant.

## Investigation of a steam generator tube rupture accident

It means that the operational data from Bushehr NPP have been used for the purpose of assessing how RELAP5 model compares against the plant data.

# Investigation of a steam generator tube rupture accident

## VVER 1000 Nuclear Power Plant Description

the reference power plant is Bushehr NPP site.

### Characteristics :

- VVER-1000 / Model V320
- Thermal power, 3000 MW
- Four primary loops
- One turbine generator
- 1000 MW electric power
- 850 mm Inlet/outlet nozzles
- each loop includes: one main MCP and SG

# Investigation of a steam generator tube rupture accident




Fig A. General view of VVER-1000 primary loop

# Investigation of a steam generator tube rupture accident

## Description of the SGTR scenario

### Accident Scenario:

- possible failures of the safety systems
- loss of power to the power unit auxiliaries
- failure of two diesel generators
  - ❖ emergency feed-water system
  - ❖ additional boron injection system
  - ❖ high-pressure emergency boron injection

## Investigation of a steam generator tube rupture accident

The most conservative version of damage is supposed as an instantaneous break with an equivalent diameter of 100 mm of steam generator cold collector in the area of lower row of heat exchanging tubes is created.

# Investigation of a steam generator tube rupture accident

## RELAP5/MOD3.2 Model

The Relap5 Model was developed for analysis of:

- operational occurrences
- abnormal events
- design basis scenarios

# Investigation of a steam generator tube rupture accident

## The systems were modeled by Relap5:

- reactor core
- reactor vessel
- MCPs
- SGs
- PRZ
- steam lines
- main steam header
- emergency protection system
- make up system
- safety injection system
- steam dumping devices
- main feed water system

# Investigation of a steam generator tube rupture accident

The reactor vessel model includes:

- downcomer
- lower plenum
- outlet plenum

The pressurizer (PRZ) system includes:

- heaters
- spray
- pressurizer relief capability

# Investigation of a steam generator tube rupture accident

The safety system includes:

- accumulators
- high and low pressure injection systems
- reactor scram system

The steam generators system include:

- heat exchanger tubes
- steam dryer
- steam line

# Investigation of a steam generator tube rupture accident

RELAP5 heat structure components are:

- fuel rods
- vessel structural internals
  - ❖ core barrel
  - ❖ core baffle
  - ❖ lower and upper plates
  - ❖ protective tube block
  - ❖ the reactor vessel

# Investigation of a steam generator tube rupture accident

- Steam generator heat structure
  - ❖ hot header wall
  - ❖ cold header wall
  - ❖ heat transfer tubes

# Investigation of a steam generator tube rupture accident




Fig B. Reactor Core Relap5 Model

# Investigation of a steam generator tube rupture accident




Fig C. Steam Generator Relap5 Model

# Investigation of a steam generator tube rupture accident

## Initial Conditions:

*Table 1. Comparison of initial conditions between measured plant parameters and RELAP5 calculations*

<i>Parameters</i>	<i>BNPP Value</i>	<i>Relap5 calculation</i>
Core power, MW	3120	3120
Primary side pressure, MPa	15.7±.3	16.0
Cold leg #1 temperature, K	565.0	567.0
Cold leg #2 temperature, K	565.0	567.0
Cold leg #3 temperature, K	565.0	567.0
Cold leg #4 temperature, K	565.0	567.0
Hot leg #1 temperature, K	598.0	598.0
Hot leg #2 temperature, K	598.0	598.0
Hot leg #3 temperature, K	598.0	600.0
Hot leg #4 temperature, K	598.0	600.0
Core flow rate, kg/s	16400.0	16600.0
Loop #1 flow rate, kg/s	4100.0	4150.0

# Investigation of a steam generator tube rupture accident

<i>Parameters</i>	<i>BNPP Value</i>	<i>Relap5 calculation</i>
Loop #2 flow rate, kg/s	4100.0	4150.0
Loop #3 flow rate, kg/s	4100.0	4150.0
Loop #4 flow rate, kg/s	4100.0	4150.0
Pressurizer water level, m	7.8	7.8
Water level in SG#1, m	1.87	2.0
Water level in SG#2, m	1.87	2.0
Water level in SG#3, m	1.87	2.0
Water level in SG#4, m	1.87	2.0
Secondary side pressure, MPa	6.37	6.3

# Investigation of a steam generator tube rupture accident

## Transient scenario:

The accident of a primary-to-secondary leak could be identified by the following symptoms:

- increase in activity in the affected SG steamline ( $10^{-3}$  msv/h) ;
- decrease in the primary coolant pressure;
- increase in level in the affected SG (+300 mm);
- PRZ level lowering (less than 4 m).

# Investigation of a steam generator tube rupture accident

Table 2. Chronological sequence of transient events

No. Description of event	<i>PSAR</i> value, sec	<i>RELAP5</i> calculated results, sec
1. SG-2 cold collector breaks ( 100.0 mm equivalent diameter )	0.0	0.0 + 200.0
2. RCP set trip of affected loop	9.75	9.750 + 200.0
3. Generation of radiation signal	10.0	No data
5. Reactor SCRAM	11.20	11.20 + 200.0
6. Turbine stop valve closure	11.40	11.40 + 200.0
7. diesel-generators start-up	12.80	12.80 + 200.0
8. SG-2 BRU-A opening	13.50	15.0 + 200.0
9. Additional boron injection start to PRZ	41.75	45.0 + 200.0
10. End of RCP set coastdown of operable loops	87.0	87.0 + 200.0
11. Closing of BRU-A of affected SG-2	130.0	130.0 + 200.0
12. HPIS-(loop 3,4) start injection	140.0	150.0 + 200.0
13. EFW (SG 3,4) start injection	1000.0	1050.0 + 200.0
14. Filling of operable SGs 3,4 to the nominal water level	2200.0	2250.0 + 200.0
15. End of calculation	5000.0	5000.0 + 200.0

# Investigation of a steam generator tube rupture accident

## Results and discussion

# Investigation of a steam generator tube rupture accident

$$\Delta P = P_p - P_s \approx 9.5 \text{ Mpa}$$

$$\dot{m}_{(leak)} \uparrow$$





Fig 1. Primary to secondary leak

# Investigation of a steam generator tube rupture accident

*Scram (14.7 Mpa )*



*Fig 2. Pressure at the core outlet*

# Investigation of a steam generator tube rupture accident




Fig 3. Coolant temperature at the core outlet

# Investigation of a steam generator tube rupture accident

$$P_s \hat{BRU} = A(SG's 1,3,4) \downarrow (SG's 3,4)$$





Fig 4. Coolant temperature at the core inlet

# Investigation of a steam generator tube rupture accident

*Loss-of-power  $\Rightarrow$  RCPs-trip*



*Fig 5. Coolant flow rate at the core inlet*

# Investigation of a steam generator tube rupture accident

## Conclusions:

- Although the calculation dealing with the consideration of the SGTR accident is a very conservative version of the damage, according to the present results acceptance design criteria is met.
- In the PSAR of the Bushehr NPP, DINAMIKA-97 code was used to evaluate the SGTR accident. According to the results obtained in this report, RELAP5 correctly predicts the behavior of the main plant parameters in comparison with the reported PSAR data.

***Thank u !!!***